

Experimental Study of Heat Transfer Enhancement in a Rectangular Duct Channel with Delta Wing Vortex Generator

Nikhil Kamlapure, Prof. Shivanand Talwar, Prof. Dr. P. A. Patil

Abstract—The influence of delta wing vortex generators on the wall of rectangular duct has been investigated in this study. The angle of attack of vortex generators systematically varied in this study to determine its effect on the heat transfer within the rectangular duct of hydraulic diameter. The effect of delta wing vortex generators at different angle of attack on pressure drop, heat transfer coefficient, friction factor, Nusselt number are reported for the Reynolds number based on the duct hydraulic diameter in the range of 8000-20000. The experimental results obtained with vortex generator is placed in comparison with the experimental results obtained by without vortex generator to define heat transfer enhancement factor in a duct. The experimental results of the present study for friction factor and Nusselt number in smooth rectangular duct agree well with values estimated from correlations proposed by Blasius and Dittus-Boelter respectively.

Index Terms—Heat transfer, Pressure drop, Delta wing type of vortex generator, Nusselt number, Friction factor.

I. INTRODUCTION

In many of industrial engineering applications several convective heat transfer methods are employed to improve the thermal performance of heat transfer devices such as treated surface, rough surface as well as incorporation of inserts like vortex generators, turbulence promoters etc. Therefore the heat transfer applications considering internal flow and mixed convection in a non-circular ducts and channels have been studied by many of researchers. For many of industrial applications it becomes more essential to improve the heat transfer coefficient and reducing pressure drop due limited source of operation such as in heat exchangers, high temperature gas turbine and electronic component.

For the enhancement of heat in a rectangular duct channel we are using passive method of heat enhancement technique, which is again classified in to longitudinal wise and transverse wise heat enhancement technique. Vortex generator is one of the method of insertion type which is found to enhancing the heat in a variety of industrial applications.

A vortex generator is considered as a passive flow control device which modifies the boundary layer fluid motion bringing momentum from the outer region into the inner region. The basic principle of vortex generator is to induce the secondary flow which will disturb the thermal boundary layer developed along the wall and removes heat from the wall of

the duct due to turbulence. The experiments were conducted to study the heat transfer and pressure drop in a rectangular duct channel by using the transverse type of delta wing vortex generator.

The experimental study on the behavior of a unique longitudinal vortex generator embedded in a developing turbulent boundary layer with a zero pressure gradient.^[1] At the punched longitudinal vortex generators in the form of winglets in staggered arrangements were used to observe the results of vortex formation, pressure distribution, velocity field, temperature fields, local heat transfer distribution in a heat exchanger and the global results for the oval tubes with two to four staggered winglets presented and compared.^[2]

The comparison of fully developed heat transfer and friction factor characteristics has been made in the rectangular duct channel with roughened at five different shapes.^[3] The implications of geometrical parameters of delta winglet vortex generators on heat transfer and pressure loss characteristics in a circular duct channel were evaluated.^[4]

For the rectangular duct, the parameter examined were: flow velocity from 0.5 to 3.4 m/s, Reynolds number from 3000 to 20,000 and results were reported with and without mounting of the longitudinal vortex generators.^[5] The decaying swirl flow was produced by the insertion of vortex generators with propeller type of geometry and at three different positions of the vortex generator in the axial direction are examined.^[6]

The heat transfer and pressure drop performance of a full-scale heat exchanger was studied before and after addition of wing type of vortex generators in two different configurations and also examined the winglet configurations at single vortex generator pair at the leading tube and three vortex generator array placed at alternate tubes.^[7] The experimental study of flow structure in horizontal equilateral triangular ducts having double rows of half delta wing type of vortex generators mounted on the duct.^[8] This paper deals with heat transfer enhancement and pressure loss penalty inside a rectangular duct with a delta wing type of vortex generator.

II. DESCRIPTION OF EXPERIMENTAL SETUP

Experiments will be performed as per the figure depicted in fig. 1. The experimental setup consists of a rectangular duct channel of hydraulic diameter of 300mm and length of 900mm and for measuring the pressure of test section through two pressure taps. Air blower provides air at the inlet of the duct passed through flow control valve and an orifice-meter. A simple U-tube manometer is used to measure the pressure heads across the duct channel.

Nikhil Kamlapure, Mechanical Department, JSPM's Jayawantrao Sawant College of Engineering, Hadapsar, Pune-28, India, 8605694880.

Prof. Shivanand Talwar, Mechanical Department, JSPM's Jayawantrao Sawant College of Engineering, Hadapsar, Pune-28, India, 9527788907.

Prof. Dr. P. A. Patil, Mechanical Department, JSPM's Jayawantrao Sawant College of Engineering, Hadapsar, Pune-28, India, 9765542844.

The rectangular duct is roughened by using delta wing type of vortex generators placed in a series and at different angle of attack. The duct of 900mm in length is surrounded by the heater for heating of duct and air moving inside of duct. The vortex generators are stickled on the bottom surface of the duct channel. These delta wing type of vortex generators are made up of 0.5mm thick stainless sheet and placed at different angle of attack on the bottom surface of the duct.

The high velocity air from the blower is supplied to duct through flow control valve and orifice meter where the pressure is given to rise. As air is leaving the orifice meter it enters in to the rectangular duct surrounded by heating element and gets heated. The variation in the temperature inside the duct is measured by the fourteen thermocouples placed on the duct surface.




Fig.1: Experimental Setup

A. Geometry of Vortex Generator

For analyzing the flow characteristics and its effect on the heat transfer the delta wing type of vortex generator is mounted on the bottom surface of the duct having L, H and W along with the aspect ratio given by W/H. The parameter of vortex generator effecting the friction factor is shown in fig.2 (Nalawade M. K., 2006).




Fig.2(a): Delta wing vortex generator




Fig.2(b): Geometry of delta wing vortex generator

Axial pitch (P): The axial distance between adjacent vortex generators is known as pitch of the vortex generator.

Vortex generator height (e): The distance between the tip of vortex generator to the surface of the wall where vortex generator is mounted.

Chord length(c): The distance of tip of vortex generator to the base of the vortex generator is known as chord length.

Vortex generator base (b): The surface of vortex generator stickled on the wall surface of the duct is called as vortex generator base.

B. Specifications of Setup:

1. Inner diameter of pipe (d1) = 0.06m.
2. Diameter of Orifice (d0) = 0.03m
3. Capacity of blower = 0.56h.p.

4. Range of Ammeter = 0 to 5 amp.
5. Range of Voltmeter= 0-270V ac.
6. U-tube manometer = 0-300 mm
7. Calibrated thermocouple(K type)= 0^oC to 1350 ^oC
8. Nichrome wire (resistivity=1.5 x 10⁻⁶Ωm) heater wound around test section.

C. Specification of Vortex Generator:

1. Number of Delta wing VG = 16
2. Pitch (P)= 50mm
3. Base (b) = 30mm
4. Chord length (c) = 37.5mm
5. Angle of attack = 30^o, 45^o, 60^o

III. DATA REDUCTION

For investigating the heat transfer and flow friction behaviors in a rectangular duct with the implication of insertion of a delta wing type of vortex generators we requires experimental calculations such as, average heat transfer coefficients are evaluated from the local measured temperatures and heat inputs. As heat is uniformly supplied to the air and the temperature difference of wall surface and fluid i.e. air (T_s-T_b), average heat transfer coefficient will be calculated from the measured data as:

$$Q_{air} = Q_{conv} = m C_p (T_o - T_i) = VI$$

where,

- T_i – inlet temperatures of air
- T_o – outlet temperatures of air
- V – Voltage supplied to the heater
- I – Current supplied to the heater

Heat flux is calculated as,

$$q = \frac{Q_{air}}{\text{Surface Area}}$$

The experimentation was done at constant heat supply and the calculations are performed to obtain the results. A sample observation table is shown below showing the parameters need to be observed during experimentation.

Table 1: Sample observation table

Sr. No.	Temperature °C					Manometer Difference	
	T ₁	T ₂	...	T ₁₃	T ₁₄	Orifice	Across the duct
						h _w	H _w

Where,

1. T₂ to T₁₃ are the surface temperatures
2. T₁ and T₁₄ are the ambient air temperatures at inlet and outlet of duct.
3. h_w and H_w is U-tube manometer difference in mm.
4. Avg. Surface Temp.,

$$T_s = (T_2 + T_3 + \dots + T_{13}) / 12$$

5. Avg. Temp of air,

$$T_b = (T_1 + T_{14}) / 2$$

From table of properties of air required parameters can be taken.

6. Manometer difference = water head = h_w

$$7. \text{ Air head, } h_a = h_w \left(\frac{\rho_w}{\rho_a} \right)$$

where,

$$\rho_w = \text{Density of water} = 1000 \text{ kg/m}^3$$

$$f = 0.046Re^{-0.2}$$

Flow rate of air through Orifice-meter,

$$Q_a = C_d \frac{A_o A_1}{\sqrt{A_o^2 - A_1^2}} \sqrt{2g \left[\frac{\rho_w}{\rho_{air}} - 1 \right] H}$$

where,

A_1 = Area of pipe

A_o = Area of orifice

C_d = Co-efficient of discharge

Mass flow rate, $\dot{m} = Q_a \times \rho_a$

Velocity of air, $V = Q_a / A$

where,

A = cross sectional area of pipe.

Heat carried out, $Q = \dot{m} \times C_p \times (T_4 - T_1)$

$$h = \frac{Q}{A (T_s - T_b)}$$

where,

h = heat transfer coefficient.

T_s = surface temperature

The Reynolds number based on duct hydraulic diameter is,

$$Re = \frac{VD_h}{\nu}$$

where,

V = velocity of the fluid.

D_h = Hydraulic Diameter of Duct

ν = Kinematic viscosity of the fluid.

The experimental Nusselt number is calculated as:

$$Nu = hD/k$$

Where,

h = heat transfer coefficient

k = thermal conductivity of fluid

D = diameter of test section i.e. Hydra. diameter

For the internal flow if Reynolds number (Re) exceeds by 4000 then the flow is turbulent. Once the type of flow is decided then the Nusselt number can be calculated. The theoretical Nusselt number can be calculated (i.e. without considering friction) and then calculated by considering friction which will be experimental Nusselt number,

$$Nu_{th} = 0.023 \times (Re)^{0.8} \times (Pr)^{0.4}$$

This equation is called Dittus-Boelter equation.

$$f_s = (1.82 \log_{10} Re)^{-1.64} \times 10^{-2}$$

This equation is used to find friction factor called as Petukhov equation for smooth surface.

where,

f_s = Friction factor for smooth tube.

Re = Reynolds number.

The actual pressure drop & friction factor is calculated with the help of tapping at both the ends of test pipe connected to U-tube manometer.

The friction factor is calculated from the formula given below:

$$f = \frac{\Delta P}{L \cdot \rho_a \cdot \frac{V^2}{2}}$$

where,

ΔP = pressure difference at both ends of test pipe.

L = length of test section.

The friction factor for the fully developed turbulent flow in smooth duct ($10^4 < Re < 10^6$) is given by Blasius equation as,

The thermal performance enhancement factor, defined as the ratio of the heat transfer coefficient of a duct with VG, h to that of a smooth duct, h_o , at an equal pumping power is given by:

$$TEF = \eta = \frac{(Nu / Nu_o)}{(f/f_o)^{1/3}}$$

By using above methodology for the calculation of heat transfer and pressure drop will be carried out for determining the heat transfer enhancement for the defined duct channel.^[9]

IV. RESULTS AND DISCUSSIONS


A. Performance evaluation

The experimental results on heat transfer and friction factor in a rectangular duct are first of all obtained for the Nusselt number and friction factor, by using Dittus-Boelter and Blasius equation. Meanwhile the heat loss, Reynold's number, heat transfer coefficient is calculated for different angle of attack of vortex generator.

The Nusselt number ratio i.e. Nu/Nu_o , defined as ratio of implication of insertion Nusselt number to the Nusselt number of smooth rectangular duct.

The isothermal friction factor i.e. f/f_o , defined as implication of insertion friction factor to the friction factor of smooth rectangular duct. Finally, the graph of Reynold's number v/s heat transfer coefficient, Reynold's number v/s Nusselt number, Reynold's number v/s friction factor were plot to determine the thermal performance enhancement within duct at different angle of attack of Vortex Generator

A. Reynold's Number v/s heat transfer coefficient: Reynold's Number v/s Heat transfer coefficient




Graph 1: Re v/s h

The plot of Reynold's number v/s heat transfer coefficient at different angle of attack of vortex generator to discuss the heat transfer in a duct and will be observed maximum at 30° of vortex generator due to proper mixing of a fluid in a duct because of the increased blockage of a fluid within the duct will increase the mixed fluid convection and as a result the heat transfer coefficient of a duct is increased.

B. Friction factor ratio for rectangular duct:

For the rectangular duct from the number of readings were taken by placing the vortex generator of different angle of attack, the friction factor value for 30°, 45°, 60° was reported and compared in above plot. Now the friction factor for vortex

generator at different angle of attack is compared with smooth rectangular duct without vortex generator.




Graph 2: Re v/s fcal/fb

The ratio of friction factor with vortex generator to without vortex generator calculated by Blasius is compared to determine the increase or decrease in friction factor for a used insert with reference to smooth duct. If the friction factor ratio for the inserts is low then the vortex generator is best suited for the designed duct of defined dimensions. The graph shown above discusses the friction factor ratio with inserts with reference to smooth duct against the Reynold’s number.

C. Nusselt number ratio for rectangular duct:


The ratio of Nusselt number with vortex generator to without vortex generator calculated by Dittus-Boelter is compared to determine the increase or decrease in heat transfer for a used insert with reference to smooth duct. If the Nusselt number ratio for the inserts is greater then the vortex generator is best suited for the duct of defined dimensions. The graph shown below discusses the Nusselt number ratio with inserts with reference to smooth duct against the Reynold’s number.



Graph 3: Re v/s Nu_{cal}/Nu_{DB}

D. Thermal Enhancement Factor(TEF):

For the proposed test section the thermal enhancement factor should be always more than 1, if it less than 1 then inserts or duct is redesigned and if it is more than 1 then the heat transfer enhancement method is preferred for the designed duct dimensions.



Graph 4: Thermal Enhancement Factor

V. CONCLUSION

An experimental study was performed to determine the airflow friction inside the rectangular duct, heat transfer coefficient and enhancement in heat from the duct by, the implication of insertions like transverse type of delta wing vortex generator at different angle of attack. From the results of friction factor and Nusselt number we can clearly describe the heat transfer enhancement in a rectangular duct channel with and without vortex generator. Among different angle of attack of vortex generator the Nusselt number, Reynold’s number, heat transfer coefficient and friction factor variation was seen best suited at an angle of 30° of vortex generator. Meanwhile the Thermal Enhancement Factor(TEF) was also found to be highest at lower Reynold’s number.

REFERENCES

- [1] Shakaba, Mehta R. D., and Bradshaw P., (1985), Longitudinal vortices embedded in turbulent boundary layers. Part 1. Single vortex, *J. Fluid Mech.*, Vol. 155, pp 37-57.
- [2] Chen Y, Fiebig M, Mitra N.K, (2000), Heat transfer enhancement of finned oval tubes with staggered punched longitudinal vortex generators, *International Journal of Heat and Mass Transfer* 43, pp.417-435.
- [3] Ahn S. W., (2001), The effect of roughness types on friction factors and heat transfer in roughened rectangular duct, *Heat Mass Transfer*, vol. 28, No. 7, pp. 933-942.
- [4] Yakut K, Sahin B, Celik C, Alemdaroglu N, and Kurnuc A, (2005), Effects of tapes with double-sided delta-winglets on heat and vortex characteristics, *Applied Energy*, Vol. 80, pp 77-95.
- [5] Qiuwang Wang, Qiuyang Chena, Ling Wang, Min Zenga, Yanping Huangc, Zejun Xiaoc, (2007), Experimental study of heat transfer enhancement in narrow rectangular channel with longitudinal vortex generators, *Nuclear Engineering and Design*, vol.237, pp. 686-693.
- [6] Betu Ayhan Sarac, Tulin Bali, (2007), An experimental study on heat transfer and pressure drop characteristics of decaying swirl flow through a circular pipe with a vortex generator, *Experimental Thermal and Fluid Science*, Vol.32, pp.158-165.
- [7] Joardar A, Jacobi A.M., (2008), Heat transfer enhancement by winglet-type vortex generator arrays in compact plain-fin-and-tube heat exchangers, *International journal of refrigeration* 31, pp.87 - 97.
- [8] Azize Akcayoglu, (2010), Flow past confined delta-wing type vortex generators, *Experimental Thermal and Fluid Science*, Vol.35, pp.112-120.
- [9] Pongjet Promvongc, Sompol Skullong, Sutapat Kwankaomeng, Chinarak Thiangpong, (2012), Heat transfer in square duct fitted diagonally with angle-finned tape.Part 1: Experimental study, *International Communications in Heat and Mass Transfer* 39, pp. 617-624.

Nikhil Kamlapure is pursuing his Post Graduation in Heat-Power (Mechanical Department) from JSPM’s Jayawantrao Sawant College of Engineering, Hadapsar, Pune-28, India. He has completed his B.E. from University of Pune in 2014.

Prof. Shivanand Talwar is Assistant Professor in Department of Mechanical Engg., JSPM’s Jayawantrao Sawant College of Engineering, Hadapsar, Pune-28, India. He has 05 years of teaching experience and 01 year industrial experience. He has completed his M.Tech (Thermal) form VTU Belgaon, India.

Prof. Dr. P. A. Patil is Head of Mechanical Engineering Department, JSPM’s Jayawantrao Sawant College of Engineering, Hadapsar, Pune-28, India. He has 19 years of teaching and 1 year industrial experience. His area of specialization is in Refrigeration and Air-Conditioning, Fluid Mechanics and Heat Transfer.